



SUPPLEMENT TO CERTIFICATE No CF291 SUPPLEMENT No. 291-187581

This supplement is issued as an amendment to the Certificate of which it constitutes an integral part. It should be read in conjunction with the Certificate and any other supplements in force at the time. Supplements are incorporated into Certificates at the time of their re-issue.

SCHOTT UK LIMITED

Drummond Road, Stafford. ST16 3EL
Tel: 01785 223166 Fax: 01785 223522

CERTIFIED PRODUCTS

Pyran S Fire Resisting Glass

SCOPE OF SUPPLEMENT

Pyran S may be laminated with LC or SPD SmartGlass interlayer for applications up to 120 minutes and as a component within IGU's up to 90 minutes, subject to the conditions specified in CF291 relating to the use of laminated glass (with specific regard to exposure direction).

Issued for and on behalf of CERTIFIRE

A handwritten signature in black ink, appearing to read "A.G. Deakin".

A G Deakin - Manager
Issued: 5th November 2009
Valid to: 8th October 2012

